

DMX MEMBRANES LIMITED

ACOUSTICAL PERFORMANCE TEST REPORT

SCOPE OF WORK

ASTM E90 AND ASTM E492 TESTING ON
5 MM LVT OVER DMX SOUND GUARD UNDERLAYMENT

SPECIMEN TYPE

203 mm Concrete Slab with Suspended Ceiling and Isolated Subfloor

REPORT NUMBER

S7646.01-113-11-R0

TEST DATE

07/10/25

ISSUE DATE

07/24/25


PAGES

14

DOCUMENT CONTROL

RTTDS-R-AMER-Test-2844 (03/23/22)

© 2017 INTERTEK



TEST REPORT FOR DMX MEMBRANES LIMITED

Report No.: S7646.01-113-11-R0

Date: 07/24/25

REPORT ISSUED TO

DMX MEMBRANES LIMITED

165 Orenda Road

Brampton, Ontario L6W 1W3 CANADA

SECTION 1

SCOPE

Architectural Testing, Inc. (an Intertek company) dba Intertek Building & Construction (B&C) was contracted by DMX Membranes Limited to perform testing in accordance with ASTM E90 AND ASTM E492 on 5 mm LVT over DMX Sound Guard Underlayment. Results obtained are tested values and were secured by using the designated test methods. Testing was conducted in the VT test chambers at Intertek B&C located in York, Pennsylvania.

This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.

SECTION 2

SUMMARY OF TEST RESULTS

DATA FILE NO.	S7646.01
SERIES/MODEL:	5 mm LVT over DMX Sound Guard Underlayment
STC	63
IIC	74
HIIC	90

COMPLETED BY: Corey S. Kohler
Technician - Acoustical
TITLE: Testing
SIGNATURE:
DATE: 07/24/25

REVIEWED BY: Daniel B. Mohler
Project Manager - Acoustical
TITLE: Testing
SIGNATURE:
DATE: 07/24/25

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

